

CITY OF GLENDALE
FIRE DEPARTMENT

☐ Fire Prevention Section
420 W. Harvard Street
Glendale, California 91204 - 1395

☒ Hazardous Materials Unit
Environmental Management Center
780 Flower Street
Glendale, California 91201-3057

RICHARD E. HINZ
Fire Chief

To: PENNOYER DODGE
6628, 6634, 6650 SAN FERNANDO RD.
Re: ANNUAL FIRE INSPECTION
On: 8/18/97 an inspection was made of the above referenced property.

DEPARTMENT USE ONLY:	
MLI #:	_____
Occupancy:	_____
U & O #:	<u>11563</u>

Your attention is called to the following item(s) which must be corrected in order to meet the minimum requirements for fire and life safety:

- ① REMOUNT YOUR FIRE EXTINGUISHERS.
 - Ⓐ NOT MORE THAN 5' ABOVE THE FLOOR.
 - Ⓑ LOCATED IN A CONSPICUOUS AND ACCESSIBLE AREA.
- ② INSTALL CHAINS OR RACK FOR ALL COMPRESSED GAS CYLINDERS.
- ③ USE OF ELECTRICAL CORDS IN LIEU OF FIXED PERMANENT WIRING IS PROHIBITED.
- ④ PROVIDE SECONDARY CONTAINMENT FOR ALL DRUMS 55 GALLONS OR GREATER, WHICH INCLUDE HAZARDOUS MATERIALS OR WASTE.

9-29-97 ALL CLEAR. S. PARRISH

You are hereby notified to correct the condition(s) listed above. A reinspection will be made on or about SEPT. 22, 1997. Failure to comply with this notice may result in a legal action being filed against you by the City Attorney.

Inspector: STEVE PARRISH Phone: (818) 548-4030 Telephone Hours: 7:30 - 8:30 a.m. and 4:30 - 6:00 p.m.

I have received a copy of this notice: _____
(Signature of Owner or Owner's Agent)